

Dematic Support

Joe Certo

[Home](#)
[Cases](#)
[Contacts](#)
 Case  
**00066755**
[Printable View](#)[« Back to List: Cases](#)**Case Detail**

Case Number 00066755

Previous Case ID  11097752Case Owner  Bud Van SullichemAccount Name Certo Brothers - West Seneca, NYContact Name  Bill MillerStatus  ClosedCategory  ElectricalPriority  2Priority Description  System partially down**Information**

Subject Super Buffer not releasing after a power outage

Description Super Buffer not releasing after a power outage

Resolution  Connected to PLC and changed N157:12 from 2 to 1.**System Information**

Date/Time Opened 12/9/2009 7:33 PM

Date/Time Closed 12/11/2009 3:20 AM

Created By Bud Van Sullichem, 12/9/2009 7:33 PMLast Modified By Derek Camp, 1/22/2015 8:45 AM**Comments**

### Comments

Public Comment	Name	Date Time
Connected to PLC and changed N157:12 from 2 to 1.	Bud Van Sullichem	9/22/2014 9:44 AM

[Back To Top](#)

Always show me  [more](#) records per related list